

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7151-0410:0163 Page 1 of 1

CATEGORY: 7151 -- BOXES/PULL STATIONS-HAZARDOUS LOCATIONS

LISTEE: Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268
Email: mum@hochiki.com

DESIGN: Model HPS-SA-EX/WP with or without the suffix DA-C non-coded, explosion proof, weather proof manual pull stations. These devices consist of a switch and terminal block mounted within an explosion proof enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 120 VAC, 10 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm manual pull stations for use with separately listed compatible fire alarm control units. Suitable for use outdoor and in Class I, Group B, C and D; Class II, Group E, F and G hazardous locations. Refer to listee's Installation Instruction Manual for details.

*These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition with California amendments except for models with suffixes -DAH.

XLf: 7151-1039:0104

*Updated 08-27-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division