

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0410:0178

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268
Email: mum@hochiki.com

DESIGN: Models DSC-EA Rate-of-rise heat detector. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detector when used in conjunction with listed compatible HSB-100 base (CSFM Listing No. 7300-0410:132) and separately listed compatible control units.

12-15-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division